

**PITTSBURG UNIFIED SCHOOL DISTRICT
INDEPENDENT LEARNING CENTER**

ADDENDUM NO. TWO

PROJECT: Independent Learning Center
1151 Stoneman Avenue, Pittsburg, CA 94565

DATE: February 10, 2023

OWNER: Pittsburg Unified School District
2000 Railroad Avenue
Pittsburg, CA 94565

DSA FILE NO.: 7-H6
DSA APP. NO.: 01-120174

DRAWINGS

1. ITEM NO. D2-1

Reference: DATA PORT REVISION

Description: The District has revised their requirements for data ports at the following locations:

1. Each Office – 8 data ports total – of the data outlet locations shown, provide 4 ports at one location adjacent to desk (we will provide the location during construction – assume the furthest from the IDF) and 2 additional data outlets with 2 ports each.
2. Reception Desk – 4 data ports adjacent to desk, and one additional data outlet with 2 ports.
3. Meeting rooms – provide 2 data ports at each outlet shown.
4. Total ports noted above - 134

2. ITEM NO. D2-2

Reference: RACK AND PATCH PANELS AT IDF

Description: 1. Provide 2-post rack with (3) 48-port patch panels instead of wall mounted cabinet with (1) 48-port patch panel for the IDF. Locate IDF rack along the north wall with 3' minimum clearance from the east and the west. Relocate the intrusion alarm key pad further to the east on the north wall to provide clearance required for the IDF rack.

2. Provide all components shown on Sheet E3.00 for the IDF.

END OF ADDENDUM NO. TWO